



City of Riverbank
Development Services Department
Planning • Building • Code Enforcement
6617 Third Street, Riverbank, CA 95367
Mailing Address: 6707 Third Street, Riverbank, CA 95367
Office (209) 863-7128 Fax (209) 869-7126

“CENTER FEED BREAKER INFORMATION”

When connecting per CEC 705, on the load side, please provide the following for Center feed Breakers:

1. Provide a note on the coversheet of the plans to indicate that the system is a Center feed Breaker installation.
2. Provide load calculations for the main service/bus per CEC 220.
3. Provide a panel schedule. Include all continuous & non-continuous loads that the panel is serving. For example, accessory buildings, swimming pools, etc.
4. Electrical plans are to be stamped by a State of California Licensed Electrical Engineer. Electronic signatures are ok, unless otherwise required.
5. Verify local utility requirements and provide any necessary documentation required w/ the submittal. For example, some utility providers may require a signature of acceptance from the Building Department. These letters are required to be site specific.